

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4485-1551:102 Page 1 of 1

CATEGORY: Opening Protection (Firestopping)

LISTEE: W. R. Grace & Co. – Conn., 62 Whitmore Ave., Cambridge, MA 02140
Contact: Amal Tamim (617) 498-4441

DESIGN: Flame-Safe C705 Cable Coating Compound thru penetration firestopping. Refer to listee's data sheet for detailed product description and considerations.

INSTALLATION: In accordance with listee's printed installation instructions, WHI Listing Directory, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product name and Warnock Hersey (WHI) label.

APPROVAL: Listed as a 1 and 2 hour fire-rated through penetration firestopping under a fluted steel deck assembly and Gypsum wallboard and steel stud wall assemblies. Refer to manufactures data sheet, WHI Design No. IPC/PV 120-03 (Report WHI-495-PSV-1094) for detailed assemblies.

NOTE: Formerly 4485-1162:105

08-18-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager